



NOTES:

1. INDIVIDUAL METERS ARE REQUIRED FOR EACH RESIDENTIAL UNIT UP TO AND INCLUDING TRIPLEXES.
2. SEE STANDARD DETAIL NO. W-040 FOR CONFIGURATION OF METER AND SERVICE CONNECTION.
3. METER AND PRESSURE REDUCING VALVE (PRV) LOCATIONS SHOWN IN THE PLAN ARE APPROXIMATE. FINAL LOCATIONS SHALL BE DETERMINED BY CITY INSPECTOR DURING CONSTRUCTION.
4. A PRV IS REQUIRED IF THE STATIC PRESSURE AT THE METER IS GREATER THAN 80 POUNDS PER SQUARE INCH (PSI).
5. METER BOXES SHALL NOT BE INSTALLED IN DRIVEWAY OR OTHER TRAFFIC AREA UNLESS APPROVED BY CITY ENGINEER.
6. WHEN POSSIBLE CLUSTER METER BOXES AT PROPERTY LINES.



APPROVED BY	L. OLIVE
DATE	07/31/2008
REF STAD SPEC	

DEPARTMENT OF PUBLIC WORKS
STANDARD DETAILS
 WATER METER INSTALLATION LOCATIONS

STANDARD DETAIL
 NUMBER
W-070