



TYPICAL SECTION

NOTES:

1. FORMS SHALL BE TRUE TO LINE AND GRADE AND SECURELY STAKED.
2. DUMMY JOINTS SHALL BE PLACED 15 FEET ON CENTERS. DUMMY JOINTS SHALL BE 1/2" x 1-1/2".
3. THRU JOINTS SHALL BE PLACED ADJACENT TO CATCH BASINS, INLETS AND AT POINTS OF TANGENCY ON STREETS, ALLEY AND DRIVEWAY RETURNS. MAXIMUM SPACING SHALL BE 30 FT. PRE-MOLDED JOINT FILLER SHALL BE 1/2" WIDE AND CONFORM TO AASHTO DESIGN M213.
4. ALL JOINTS SHALL BE CLEAN AND EDGED.
5. CONCRETE SHALL BE CEMENT CONCRETE, CLASS 3000.
6. STEEL FORMS ONLY SHALL BE USED ON TANGENT SECTIONS. WOOD FORMS MAY BE USED ON CURVED SECTIONS.
7. FINISH SHALL BE LIGHT BROOM FINISH.
8. THE FINISHED CURB SHALL BE SPRAYED WITH A TRANSPARENT CURING COMPOUND AND COVERED BY WATERPROOF PAPER OR PLASTIC MEMBRANE IN THE EVENT OF RAIN OR OTHER INCLEMENT WEATHER. CURING TIME SHALL BE A MINIMUM OF 72 HOURS.
9. ALL CURB AND GUTTER SHALL BE PLACED ON A MIN OF 2" OF CRUSHED SURFACING TOP COURSE.
10. DUMMY JOINT 1/2" x 1 1/2" BETWEEN TYPE 1 CURB AND GUTTER AND THE SIDEWALK.



APPROVED BY	L. OLIVE
DATE	07/31/2008
REF STD SPEC	

DEPARTMENT OF PUBLIC WORKS
STANDARD DETAILS
 CEMENT CONCRETE CURB AND
 GUTTER TYPE 1

STANDARD DETAIL
 NUMBER
R-180