

**FILE COPY**

Property Address:	1105 East 5th Street
Permit Number:	105
Development Name:	NA
Lot Number:	NA
Date Inspected:	04/27/61
Inspected By:	Henry Spencer
AutoCad As-built Drawn By:	Fred Rapelyea
AutoCad Drawing Date:	1/16/07

N

E. 5th Street

Main Sewer

\* Pipe slope from property line to building is 2%. Depth of pipe at connection to building is 18". Pipe material is 4" clay tile.

