



# SIDE SEWER INSPECTION FORM

Department of Public Works • Utilities Division

City of Arlington • 154 W. Cox Street • Arlington, WA 98223 • Phone (360) 403-3526

Site Address: 117 + 117 1/2 Dunham N  
 Project Name: Joanne Douglas  
 Permit #: ~~405~~ 405  
 Firm/Developer: E + D Excavation  
 Contact Person: Dan Groendyk  
 Contractor: Earl + Dan Groendyk  
 Initial Inspection Date:

Sewer Permit #: 510  
 Lot #: \_\_\_\_\_  
 Phase: \_\_\_\_\_  
 Inspector: Zach Johnson  
 Phone: \_\_\_\_\_  
 Phone: 425-359-6198  
 Final Inspection Date: 3-7-16

Staff Comments: Complete side sewer repair from our stub to 117 + 117 1/2. Added 6" c/o 1' below grade capped. 8' behind sidewalk. (our stub looked good.)

